

Consumer Confidence Report

Annual Drinking Water Quality Report

BREESE

IL0270250

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by BREESE is Surface Water

For more information regarding this report contact:

Name Don Voss / Josh Niederhofer

Phone 618-526-7151 / 618-526-8848

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
Contaminants that may be present in source water include: <ul style="list-style-type: none">- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Some people may be more vulnerable to contaminants in drinking water than the general population.
Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact Josh Niederhofer at 618-526-8848. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at http://www.epa.gov/safewater/lead .

Source Water Information

Source Water Name	Type of Water	Report Status	Location
INTAKE (01779) NEW SHOAL CREEK RAW WATER INTAKE	SW	<u>A</u>	<u>Approximately 1150' South of Old Rt 50 bridge over Shoal Creek</u>

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 618-526-8848. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: BREESE Illinois EPA considers all surface water sources of community water supply to be susceptible to potential pollution problems, hence, the reason for mandatory treatment for all surface water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration, and disinfection. In addition, agricultural runoff within the Middle Kaskaskia River Basin contributes to the susceptibility of the Breese intakes.

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: 8.9 ppm to 2500 ppm

Lead Range: <1.0 ppb to 7.1 ppb

To obtain a copy of the system's lead tap sampling data: Josh Niederhofer 618-526-8848

CIRCLE ONE: Our Community Water Supply has has not developed a service line material inventory.

To obtain a copy of the system's service line inventory: Don Voss 618-526-7151

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	1.3	0.17	1	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	2025	0	15	2.4	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Water Quality Test Results

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na:

not applicable.

mrem:

millirems per year (a measure of radiation absorbed by the body)

ppb:

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm:

milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2025	2.1	1.9 - 2.4	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2025	54	27.4 - 47.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	62	38 - 85	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2025	0.054	0.054 - 0.054	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2025	0.6	0.615 - 0.615	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Manganese	2025	6	6.3 - 6.3	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2025	0.04	0.04 - 0.04	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2025	44	44 - 44			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2025	0.36	0 - 0.36	3	3	ppb	N	Runoff from herbicide used on row crops.

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
--	-----------------------------	----------------	-----------	--------------------------------

MAXT

Highest single measurement	0.5 NTU	0.099 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.2 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Sample Event Code/Sample Schedule	SE2	Apr 2025
Facility ID/Name	Membrane Filter Plant (Shoal Creek)	34794
Sample Point ID/Type/Name	TP04 EP	Finished Water Tap (after treatment)

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFBS	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFHpA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFHxS	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFNA	4/8/2025 12:00:00 AM	<0.004

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFOS	4/8/2025 12:00:00 AM	<0.004

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFOA	4/8/2025 12:00:00 AM	<0.004

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFDA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFDoA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFHxA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFUnA	4/8/2025 12:00:00 AM	<0.002

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	11Cl-PF3OUdS	4/8/2025 12:00:00 AM	<0.005
127420P	EPA 533	9Cl-PF3ONS	4/8/2025 12:00:00 AM	<0.002
127420P	EPA 533	ADONA	4/8/2025 12:00:00 AM	<0.003
127420P	EPA 533	HFPO-DA	4/8/2025 12:00:00 AM	<0.005
127420P	EPA 533	PFBA	4/8/2025 12:00:00 AM	<0.005
127420P	EPA 533	6:2 FTS	4/8/2025 12:00:00 AM	<0.005
127420P	EPA 533	4:2 FTS	4/8/2025 12:00:00 AM	<0.003
127420P	EPA 533	8:2 FTS	4/8/2025 12:00:00 AM	<0.005
127420P	EPA 533	PFMPA	4/8/2025 12:00:00 AM	<0.004
127420P	EPA 533	PFPeA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFMBA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFEESA	4/8/2025 12:00:00 AM	<0.003

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	NFDHA	4/8/2025 12:00:00 AM	<0.02

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFPeS	4/8/2025 12:00:00 AM	<0.004

Sample Kit ID	Method ID	Analyte Name	Collection Date	Reported Value(µg/L)
127420P	EPA 533	PFHpS	4/8/2025 12:00:00 AM	<0.003

Violations Table

1,1,1-Trichloroethane			
Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

1,1,2-Trichloroethane			
Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

1,1-Dichloroethylene			
Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

1,2,4-Trichlorobenzene			
Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Violations Table

1,2-Dichloroethane			
Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

1,2-Dichloropropane			
Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Benzene			
Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Carbon Tetrachloride			
Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Violations Table

Chlorobenzene			
Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Dichloromethane			
Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Ethylbenzene			
Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Styrene			
Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Violations Table

Tetrachloroethylene			
Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Toluene			
Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Total Organic Carbon			
Total organic carbon has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include Trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE (DBP), MAJOR	08/01/2025	08/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Trichloroethylene			
Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Violations Table

Xylenes			
Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

cis-1,2-Dichloroethylene			
Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

o-Dichlorobenzene			
Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

p-Dichlorobenzene			
Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Violations Table

trans-1,2-Dichloroethylene			
Some people who drink water containing trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

The above 21 violations are the result of ONE missed VOC water sample. Sample was missed due to a breakdown in communication between the City of Breese, IEPA and our testing laboratory.

There is no reason to believe there are any adverse health effects arising from the missed sample as we are on reduced monitoring for VOC.

There is no action you need to take at this time, sample period was for 2025.

Carbon Total / Alkalinity

Violation Description	Contaminants	Level Found	Compliance Period	PN Tier
Monitoring	Total Carbon/Alkalinity	N/A	8/1/2025 - 8/31/2025	3
Samples Required 1 Received 0	Samples arrived at laboratory out of tempature range, it was too late to resample for August Compliance Period once we were notified in early September			
	There are no apparent adverse health effects nor any actions your should take as our July and September samples were in compliance as usual.			